



Product Service

Attestation of Conformity

No. N8A 125519 0002 Rev. 00

Holder of Attestation: **Solution Distribution Europe Sàrl**

Lampertskaul 15
9952 Drinklange
LUXEMBOURG

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062443001-00

Date, 2024-04-03

(Zhulin Zhang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 125519 0002 Rev. 00

Model(s):

KODAK SOLAR MODULES 420W FBBI AM,
 KODAK SOLAR MODULES 425W FBBI AM,
 KODAK SOLAR MODULES 430W FBBI AM,
 KODAK SOLAR MODULES 435W FBBI AM,
 KODAK SOLAR MODULES 440W FBBI AM,
 KODAK SOLAR MODULES 440W FBMO AM,
 KODAK SOLAR MODULES 445W FBBI AM,
 KODAK SOLAR MODULES 445W FBMO AM,
 KODAK SOLAR MODULES 450W FBBI AM,
 KODAK SOLAR MODULES 450W FBMO AM,
 KODAK SOLAR MODULES 500W FBMO AM,
 KODAK SOLAR MODULES 500W FBBI AM,
 KODAK SOLAR MODULES 505W FBMO AM,
 KODAK SOLAR MODULES 505W FBBI AM,
 KODAK SOLAR MODULES 550W FBMO AM,
 KODAK SOLAR MODULES 555W FBMO AM,
 KODAK SOLAR MODULES 580W FBBI AM,
 KODAK SOLAR MODULES 585W FBBI AM,
 KODAK SOLAR MODULES 600W FBBI AM,
 KODAK SOLAR MODULES 600W FBMO AM.

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.